



## Mechanical Addendum No. M01



**Project:** Watson Lake Recreation Centre – Backup Boiler Project  
**BSC Project No.:** 2023-086  
**Date Issued:** March 25, 2026  
**Page:** 1 of 1  
**Prepared by:** Jeffrey Pike, P.Eng

This addendum shall be read in conjunction with and to amend the tender documents and will form part of the Contract Documents. Include in the Bid Price all revisions as outlined in the Addendum, which will become part of the Work. Perform all such work in accordance with the requirements of the Contract Documents and this Addendum. Acknowledge receipt of this Addendum by reference in the Bid Form submitted by the bidding Contractors and ensure that all parties submitting bids are aware of all items included in this Addendum. No consideration shall be allowed for increases to the Contract price due to failure of being familiar with this Addendum.

---

### ADDENDUM SCOPE

#### **1.01 Alternate Boiler**

Question:

Please confirm if the Fulton EXE series can be acceptable equal boiler to what's listed in the schedule. See attached technical comparison sheet between P-K SC3000 and Fulton EXE 3000, drawings, and submittals.

Response:

Acceptance of Fulton EXE 3000 Boiler as an alternate boiler selection is approved based on performance and physical dimensions and is considered technically suitable option for the project. However, due to physical constraints within the mechanical room and differences in boiler dimensions, venting arrangements, and overall form factor, the Contractor shall be responsible for coordinating the final layout on site if they choose the Fulton unit.

**End of Addendum**